



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.90				Y
3					
4					
5					
6	7.88				Y
7					
8					
9	7.80				Y
10					
11					
12					
13	7.82				Y
14					
15					
16					
17	7.73				Y
18					
19					
20	7.65				Y
21					
22					
23	7.56				Y
24					
25					
26	7.57				Y
27					
28					
29					
30	7.52				Y
31					

<<Have
minimums
been met for
this day?

County: Linn Agency: LINN COUNTY

ENTRY POINT
EP-A
PWS ID 4194865
EASTGATE CENTER

Sample period: October 2023
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Brian Tarkenton
Signature: [Signature]
Date & Phone#: 11/10/23

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0