



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.22				Y
2					
3					
4					
5	8.23				Y
6					
7	8.25				Y
8					
9					
10					
11					
12	8.24				Y
13					
14					
15	8.25				Y
16					
17					
18					
19	8.25				Y
20					
21					
22	8.27				Y
23					
24					
25					
26					
27	8.26				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4194865**  
**EASTGATE CENTER**

Sample period: December 2023  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Brian Tarkenton  
Signature: [Signature]  
Date & Phone#: 1/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0