



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 7.62 | | | | Y |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | 7.60 | | | | Y |
| 6 | | | | | |
| 7 | 7.58 | | | | Y |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | | | | |
| 11 | 7.56 | | | | Y |
| 12 | | | | | |
| 13 | 7.55 | | | | Y |
| 14 | | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | | | | | |
| 18 | 7.53 | | | | Y |
| 19 | | | | | |
| 20 | | | | | |
| 21 | 7.42 | | | | Y |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | 7.42 | | | | Y |
| 28 | | | | | |
| 29 | 7.41 | | | | Y |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

ENTRY POINT
EP-A
PWS ID 4194865
EASTGATE CENTER

Sample period: March 2024
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Brigit Tarkenton
Signature: [Signature]
Date & Phone#: 4/9/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0