



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.70				Y
3	7.71				Y
4	7.58				Y
5	7.63				Y
6	7.62				Y
7	7.55				Y
8	7.60				Y
9	7.57				Y
10	7.75				Y
11	7.67				Y
12	7.56				Y
13	7.49				Y
14	7.54				Y
15	7.52				Y
16	7.89				Y
17	7.59				Y
18	7.67				Y
19	7.54				Y
20	7.55				Y
21	7.64				Y
22	7.74				Y
23	7.70				Y
24	7.5				Y
25	7.5				Y
26	7.41				Y
27	7.37				Y
28	7.54				Y
29	7.43				Y
30	7.4				Y
31	8.05				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4194865**  
**EASTGATE CENTER**

Sample period: March 2025  
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Brian Tarkenton

Signature: 

Date & Phone#: 04/01/2025 707-615-5944

Send to DWP within 10 days after end of sampling period