

Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N

← Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				y
3	7.6				y
4	7.7				y
5	7.6				y
6	7.6	215			y
7	7.6				y
8	7.7				y
9	7.6				y
10	7.7				y
11	7.6				y
12	7.6				y
13	7.6				y
14	7.7				y
15	7.6				y
16	7.5	216			y
17	7.6				y
18	7.7				y
19	7.7				y
20	7.6				y
21	7.7				y
22	7.7				y
23	7.7	212			y
24	7.7				y
25	7.6				y
26	7.6				y
27	7.7				y
28	7.7				y
29	7.6				y
30	7.7	180			y
31	7.6				y
(No = N = Excursion) Total N's					0


ENTRY POINT	
PWS ID:	<u>4195136</u>
Sytem Name:	<u>Jefferson Baptist Church</u>
Entry Point:	<u>EP-B</u>
Sample Period:	<u>May-24</u> Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA	
pH	<u>7.3</u>
Alkalinity	
Orthophosphate	
Other	

Print Name: Chris Elkins
Signature: Chris Elkins
Date: 6/3/24

Send to DWP within 10 days after end of sampling period.