


Day pH Alk Phos Other Y/N  Have minimums been met for this day?

| Day                            | pH  | Alk | Phos | Other | Y/N |
|--------------------------------|-----|-----|------|-------|-----|
| 1                              | 7.8 |     |      |       | Y   |
| 2                              | 7.9 |     |      |       | y   |
| 3                              | 7.8 |     |      |       | y   |
| 4                              | 7.8 |     |      |       | y   |
| 5                              | 7.7 |     |      |       | y   |
| 6                              | 7.8 | 185 |      |       | y   |
| 7                              | 7.8 |     |      |       | y   |
| 8                              | 7.8 |     |      |       | y   |
| 9                              | 7.8 |     |      |       | y   |
| 10                             | 7.9 |     |      |       | y   |
| 11                             | 7.8 |     |      |       | y   |
| 12                             | 7.8 |     |      |       | y   |
| 13                             | 7.8 | 188 |      |       | y   |
| 14                             | 7.8 |     |      |       | y   |
| 15                             | 7.8 |     |      |       | y   |
| 16                             | 7.8 |     |      |       | y   |
| 17                             | 7.9 |     |      |       | y   |
| 18                             | 7.8 |     |      |       | y   |
| 19                             | 7.8 |     |      |       | y   |
| 20                             | 7.9 | 165 |      |       | y   |
| 21                             | 7.8 |     |      |       | y   |
| 22                             | 7.8 |     |      |       | y   |
| 23                             | 7.9 |     |      |       | y   |
| 24                             | 7.8 |     |      |       | y   |
| 25                             | 7.8 |     |      |       | y   |
| 26                             | 7.8 |     |      |       | y   |
| 27                             | 7.9 | 165 |      |       | y   |
| 28                             |     |     |      |       |     |
| 29                             |     |     |      |       |     |
| 30                             |     |     |      |       |     |
| 31                             |     |     |      |       |     |
| (No = N = Excursion) Total N's |     |     |      |       | 0   |

| ENTRY POINT    |                                  |
|----------------|----------------------------------|
| PWS ID:        | <u>4195136</u>                   |
| Sytem Name:    | <u>Jefferson Baptist Church</u>  |
| Entry Point:   | <u>EP-B</u>                      |
| Sample Period: | <u>November-24</u><br>Month/Year |

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

| Minimum Water Quality Parameters as set by OHA |   |
|--|---|
| pH   | <u>7.3</u>  |
| Alkalinity                                     |  |
| Orthophosphate                                 |   |
| Other  |   |

Print Name: Chris Elkins  
 Signature: Chris Elkins  
 Date: 12/4/24

Send to DWP within 10 days after end of sampling period.