

Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.7	176			y
3	7.6				y
4	7.7				y
5	7.7				y
6	7.7				y
7	7.6				y
8	7.7				y
9	7.7	172			y
10	7.7				y
11	7.8				y
12	7.7				y
13	7.7				y
14	7.7				y
15	7.7				y
16	7.7	175			y
17	7.6				y
18	7.7				y
19	7.6				y
20	7.7				y
21	7.7				y
22	7.7				y
23	7.7	170			y
24	7.6				y
25	7.7				y
26	7.7				y
27	7.7				y
28	7.6				y
29	7.7				y
30	7.7				y
31	7.7				y
(No = N = Excursion) Total N's					0

ENTRY POINT

PWS ID: 4195136

Sytem Name: Jefferson Baptist Church

Entry Point: EP-B


Sample Period: January-25
Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA

pH 7.3

Alkalinity 

Orthophosphate 

Other

Print Name: Chris Elkins

Signature: Chris Elkins

Date: 2/1/25

Send to DWP within 10 days after end of sampling period.