

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.6				y
3	7.7				y
4	7.6	168			y
5	7.6				y
6	7.6				y
7	7.7				y
8	7.6				y
9	7.7				y
10	7.6				y
11	7.6	170			y
12	7.6				y
13	7.7				y
14	7.6				y
15	7.6				y
16	7.7				y
17	7.6				y
18	7.6	165			y
19	7.6				y
20	7.6				y
21	7.7				y
22	7.6				y
23	7.6				y
24	7.7				y
25	7.6	162			y
26	7.7				y
27	7.6				y
28	7.6				y
29					
30					
31					
(No = N = Excursion) Total N's					0

### ENTRY POINT

**PWS ID:** 4195136

**Sytem Name:** Jefferson Baptist Church

**Entry Point:** EP-B


**Sample Period:** February-25  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Minimum Water Quality Parameters as set by OHA**

pH 7.3

Alkalinity 

Orthophosphate

Other

**Print Name:** Chris Elkins

**Signature:** Chris Elkins

**Date:** 3/5/25

Send to DWP within 10 days after end of sampling period.