

Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

1	7.6				Y
2	7.7	185			y
3	7.6				y
4	7.7				y
5	7.7				y
6	7.7				y
7	7.7				y
8	7.6				y
9	7.7	188			y
10	7.7				y
11	7.7				y
12	7.6				y
13	7.7				y
14	7.6				y
15	7.7				y
16	7.7	182			y
17	7.7				y
18	7.8				y
19	7.7				y
20	7.7				y
21	7.7				y
22	7.6				y
23	7.6	186			y
24	7.6				y
25	7.7				y
26	7.6				y
27	7.6				y
28	7.6				y
29	7.6				y
30	7.7	196			y
31					
(No = N = Excursion) Total N's					0

ENTRY POINT

PWS ID: 4195136
 Sytem Name: Jefferson Baptist Church
 Entry Point: EP-B
 Sample Period: April-25
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA

pH 7.3
 Alkalinity 
 Orthophosphate
 Other

Print Name: Chris Elkins

Signature: Chris Elkins

Date: 5/6/25

Send to DWP within 10 days after end of sampling period.