

Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

1	7.5				Y
2	7.5				y
3	7.6				y
4	7.5				y
5	7.5				y
6	7.5	205			y
7	7.6				y
8	7.5				y
9	7.6				y
10	7.5				y
11	7.5				y
12	7.5				y
13	7.4	200			y
14	7.5				y
15	7.5				y
16	7.5				y
17	7.5				y
18	7.6				y
19	7.5				y
20	7.5	205			y
21	7.5				y
22	7.5				y
23	7.6				y
24	7.5				y
25	7.5				y
26	7.5				y
27	7.5	203			y
28	7.6				y
29	7.5				y
30	7.5				y
31	7.5				y
(No = N = Excursion) Total N's					0

ENTRY POINT

PWS ID: 4195136
 Sytem Name: Jefferson Baptist Church
 Entry Point: EP-B
 Sample Period: October-25
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA

pH 7.3
 Alkalinity 
 Orthophosphate
 Other

Print Name: Chris Elkins

Signature: Chris Elkins

Date: 11/7/25

Send to DWP within 10 days after end of sampling period.