

Day pH Alk Phos Other Y/N

Have minimums been met for this day?

1	7.5				Y
2	7.5				y
3	7.5	195			y
4	7.6				y
5	7.5				y
6	7.5				y
7					
8	7.5				y
9	7.5				y
10	7.4	196			y
11	7.5				y
12	7.5				y
13	7.5				y
14	7.5				y
15	7.6				y
16	7.5				y
17	7.6	198			y
18	7.5				y
19	7.5				y
20	7.6				y
21	7.5				y
22	7.5				y
23	7.5				y
24	7.4	194			y
25	7.5				y
26	7.5				y
27					
28					
29					
30					
31					
(No = N = Excursion)		Total N's		0	

ENTRY POINT

PWS ID: 4195136
 System Name: Jefferson Baptist Church
 Entry Point: EP-B
 Sample Period: November-25

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA

pH	<u>7.3</u>
Alkalinity	
Orthophosphate	
Other	

Print Name: Chris Elkins

Signature: Chris Elkins

Date: 12/10/25

Send to DWP within 10 days after end of sampling period.