


Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2	7.6				y
3	7.5				y
4	7.5				y
5	7.6				y
6	7.5				y
7	7.6	162			y
8	7.6				y
9	7.6				y
10	7.6				y
11	7.5				y
12	7.6				y
13	7.6				y
14	7.6				y
15	7.5				y
16	7.5				y
17	7.6				y
18	7.6				y
19	7.6				y
20	7.5	167			y
21	7.6				y
22	7.6				y
23	7.6				y
24	7.6				y
25	7.6				y
26	7.5				y
27	7.6				y
28	7.5				y
29	7.6				y
30	7.6				y
31					
(No = N = Excursion) Total N's					0


ENTRY POINT	
PWS ID:	<u>4195136</u>
Sytem Name:	<u>Jefferson Baptist Church</u>
Entry Point:	<u>EP-B</u>
Sample Period:	<u>April-19</u> 
	Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distrit excursions are cumulative)

Minimum Water Quality Parameters as set by OHA	
pH	<u>7.3</u>
Alkalinity	
Orthophosphate	
Other	

Print Name: Chris Elkins
Signature: Chris Elkins
Date: 6/1/21

Send to DWP within 10 days after end of sampling period.