


# Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N

← Have minimums been met for this day? 

Day	pH	Alk	Phos	Other	Y/N
1	7.5				y
2	7.5				y
3	7.5				y
4	7.6				y
5	7.5	196			y
6	7.6				y
7	7.5				y
8	7.5				y
9	7.5				y
10	7.6				y
11	7.6				y
12	7.6				y
13	7.5				y
14	7.6				y
15	7.6				y
16	7.6				y
17	7.5				y
18	7.6				y
19	7.6				y
20	7.5				y
21	7.5				y
22	7.6				y
23	7.6				y
24	7.6				y
25	7.6	195			y
26	7.5				y
27	7.6				y
28	7.6				y
29	7.6				y
30	7.6				y
31					
(No = N = Excursion) Total N's					0

## ENTRY POINT

**PWS ID:** 4195136  
**Sytem Name:** Jefferson Baptist Church  
**Entry Point:** EP-B  
**Sample Period:** June-21  
 Month/Year


**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

### Minimum Water Quality Parameters as set by OHA

pH 7.3  
 Alkalinity   
 Orthophosphate  
 Other

**Print Name:** Chris Elkins  
**Signature:** Chris Elkins  
**Date:** 6/30/21

Send to DWP within 10 days after end of sampling period.