

# Lead & Copper Rule Corrosion Control

**Day pH Alk Phos Other Y/N**  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2	7.6				y
3	7.6				y
4	7.6				y
5	7.7				y
6	7.6	196			y
7	7.6				y
8	7.7				y
9	7.6				y
10	7.7				y
11	7.7				y
12	7.6				y
13	7.7				y
14	7.7				y
15	7.8				y
16	7.7				y
17	7.7				y
18	7.8				y
19	7.8	200			y
20	7.8				y
21	7.8				y
22	7.8				y
23	7.7				y
24	7.8				y
25	7.7				y
26	7.8				y
27	7.8				y
28	7.7				y
29	7.8				y
30	7.8				y
31	7.8				y
(No = N = Excursion) <b>Total N's</b>					0

### ENTRY POINT

**PWS ID:** 4195136

**Sytem Name:** Jefferson Baptist Church

**Entry Point:** EP-B


**Sample Period:** July-21  
Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Minimum Water Quality Parameters as set by OHA**

pH 7.3

Alkalinity 

Orthophosphate

Other

**Print Name:** Chris Elkins

**Signature:** Chris Elkins

**Date:** 8/3/21

Send to DWP within 10 days after end of sampling period.