

# Lead & Copper Rule Corrosion Control

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.7				y
2	7.7				y
3	7.6				y
4	7.7				y
5	7.7				y
6	7.6				y
7	7.6				y
8	7.7				y
9	7.6	181			y
10	7.6				y
11	7.7				y
12	7.6				y
13	7.7				y
14	7.6				y
15	7.7				y
16	7.6				y
17	7.7				y
18	7.7				y
19	7.6				y
20	7.7				y
21	7.7				y
22	7.7				y
23	7.6	178			y
24					
25					
26					
27					
28	7.7				y
29	7.7				y
30	7.6				y
31					y
(No = N = Excursion) Total N's					0


<b>ENTRY POINT</b>	
<b>PWS ID:</b>	<u>4195136</u>
<b>Sytem Name:</b>	<u>Jefferson Baptist Church</u>
<b>Entry Point:</b>	<u>EP-B</u>
<b>Sample Period:</b>	<u>December-21</u> Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<u>7.3</u>
Alkalinity	
Orthophosphate	
Other	

**Print Name:** Chris Elkins  
**Signature:** Chris Elkins  
**Date:** 1/3/22

Send to DWP within 10 days after end of sampling period.