

# Lead & Copper Rule Corrosion Control

**Day pH Alk Phos Other Y/N**  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.5				y
2	7.5				y
3	7.6				y
4	7.5				y
5	7.4				y
6	7.5				y
7	7.5				y
8	7.6	225			y
9	7.5				y
10	7.5				y
11	7.6				y
12	7.5				y
13	7.6				y
14	7.6				y
15	7.5				y
16	7.6				y
17	7.4				y
18	7.4				y
19	7.5				y
20	7.6				y
21	7.5				y
22	7.6				y
23	7.7				y
24	7.7	223			y
25	7.7				y
26	7.5				y
27	7.6				y
28	7.7				y
29	7.6				y
30					
31	7.7				y
(No = N = Excursion) <b>Total N's</b>					0

### ENTRY POINT


**PWS ID:** 4195136

**Sytem Name:** Jefferson Baptist Church

**Entry Point:** EP-B


**Sample Period:** May-22  
Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

 **Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Minimum Water Quality Parameters as set by OHA**

pH 7.3

Alkalinity 

Orthophosphate

Other

**Print Name:** Chris Elkins

**Signature:** Chris Elkins

**Date:** 5/31/22

Send to DWP within 10 days after end of sampling period.