

# Lead & Copper Rule Corrosion Control


Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2	7.7				y
3	7.6				y
4	7.6				y
5	7.6	216			y
6	7.5				y
7	7.6				y
8	7.5				y
9	7.5				y
10	7.6				y
11	7.6				y
12	7.6	217			y
13	7.7				y
14	7.6				y
15	7.6				y
16	7.6				y
17	7.7				y
18	7.6				y
19	7.7	214			y
20	7.5				y
21	7.7				y
22	7.6				y
23	7.7				y
24	7.6				y
25	7.6				y
26	7.7	215			y
27	7.6				y
28	7.6				y
29	7.6				y
30	7.7				y
31					
(No = N = Excursion) Total N's					0

<b>ENTRY POINT</b>	
<b>PWS ID:</b>	<u>4195136</u>
<b>Sytem Name:</b>	<u>Jefferson Baptist Church</u>
<b>Entry Point:</b>	<u>EP-B</u>
<b>Sample Period:</b>	<u>September-22</u> Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<u>7.3</u>
Alkalinity	
Orthophosphate	
Other	

**Print Name:** Chris Elkins  
**Signature:** Chris Elkins  
**Date:** 10/10/22

Send to DWP within 10 days after end of sampling period.