

Day pH Alk Phos Other Y/N  Have minimums been met for this day?

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2	7.6				y
3	7.7				y
4	7.6				y
5	7.6				y
6	7.7				y
7	7.7	196			y
8	7.7				y
9	7.6				y
10	7.6				y
11	7.6				y
12	7.7				y
13	7.7				y
14	7.6	201			y
15	7.7				y
16	7.7				y
17	7.8				y
18	7.8				y
19	7.7				y
20	7.8				y
21	7.8	186			y
22	7.8				y
23	7.7				y
24					
25					
26					
27					
28	7.6	166			y
29	7.6				y
30	7.5				y
31					
(No = N = Excursion) Total N's					0

ENTRY POINT

PWS ID: 4195136

Sytem Name: Jefferson Baptist Church

Entry Point: EP-B


Sample Period: November-22
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by OHA

pH 7.3

Alkalinity 

Orthophosphate

Other

Print Name: Chris Elkins

Signature: Chris Elkins

Date: 11/30/22

Send to DWP within 10 days after end of sampling period.