

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.1				N
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	7.1				N
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4195379**

**EMERALD CHRISTIAN ACADEMY**

Sample period: 02 / 2021  
 Month/Year

Number of excursions during this month: 3

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*



Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Bill Centrella

Signature: Bill Centrella

Date & Phone#: 7/15 - 541-632-0638

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 3

*over 14 day period*