

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.6				
6					
7					
8					
9					
10					
11					
12					
13	7.3				
14					
15					
16					
17					
18					
19					
20					
21	7.5				
22					
23					
24					
25					
26					
27					
28					
29	7.4				
30					
31					

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

**ENTRY POINT
EP-A**

PWS ID 4195379

EMERALD CHRISTIAN ACADEMY

Sample period: March / 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: William Centrella
 Signature: William Centrella
 Date & Phone#: 3/30/2023 (541) 632-0638

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0