

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.9				Y
6					
7					
8					
9					
10					
11					
12	7.8				Y
13					
14					
15					
16					
17					
18					
19	7.9				Y
20					
21					
22					
23					
24					
25					
26					
27	7.8				Y
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 8

<<Have
minimums
been met for
this day?

County: Lane Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4195379

EMERALD CHRISTIAN ACADEMY

Sample period: August / 2025
Month/Year

Number of excursions during this month: 8

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Doug Gaylor

Signature: [Signature]

Date & Phone#: 8/27/2025

Send to DWP within 10 days after end of
sampling period