

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.3	12			Y
4					
5					
6					
7					
8					
9					
10	7.9	18			Y
11					
12					
13					
14					
15					
16					
17					
18	7.9	15			Y
19					
20					
21					
22					
23					
24	7.8	13			Y
25					
26					
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Lane

Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4195379

EMERALD CHRISTIAN ACADEMY

Sample period: Nov/ 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2



Print Name: Doug Gaylor

Signature: Doug Gaylor

Date & Phone#: 11/24/25 541-746-1708

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0