

Day	pH	Alk	Phos	Other	Y/N
1	7.84				Y
2	SAT				Y
3	SUN				Y
4	7.81				Y
5	7.90				Y
6	7.87				Y
7	7.89				Y
8	7.86				Y
9	SAT				Y
10	SUN				Y
11	7.89				Y
12	7.77				Y
13	7.89				Y
14	7.87				Y
15	7.89				Y
16	SAT				Y
17	SUN				Y
18	7.90				Y
19	7.90				Y
20	7.83				Y
21	7.80				Y
22	7.89				Y
23	SAT				Y
24	SUN				Y
25	7.90				Y
26	7.90				Y
27	7.76				Y
28	7.79				Y
29	7.89				Y
30	SAT				Y
31	SUN				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 95551

System Name: FALL CREEK FARM

Entry Point: LUNCH ROOM EAST SINK

Sample Period: October 2021
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: JERRY FASCINATO

Signature: 

Date: 11-4-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0