

Day	pH	Alk	Phos	Other	Y/N
1	7.61				Y
2	SAT				Y
3	SUN				Y
4	7.87				Y
5	7.85				Y
6	7.83				Y
7	7.87				Y
8	7.84				Y
9	SAT				/
10	SUN				/
11	7.88				Y
12	7.72				Y
13	7.73				Y
14	7.71				Y
15	7.77				Y
16	SAT				/
17	SUN				/
18	7.75				Y
19	7.78				Y
20	7.68				Y
21	7.60				Y
22	7.65				Y
23	SAT				/
24	SUN				/
25	7.82				Y
26	7.79				Y
27	7.80				Y
28	7.83				Y
29	7.86				Y
30	SAT				/
31	SUN				/

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 95551

System Name: FALL CREEK FARM

Entry Point: LUNCH ROOM EAST SINK

Sample Period: April 2022
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	()

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 5-2-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0