

Day	pH	Alk	Phos	Other	Y/N
1	7.78				Y
2	7.54				Y
3	7.61				Y
4	SAT				-
5	SUN				-
6	7.70				Y
7	7.64				Y
8	7.66				Y
9	7.61				Y
10	7.72				Y
11	SAT				-
12	SUN				-
13	7.80				Y
14	7.74				Y
15	7.76				Y
16	7.69				Y
17	7.70				Y
18	SAT				-
19	SUN				-
20	7.72				Y
21	7.64				Y
22	7.67				Y
23	7.71				Y
24	7.68				Y
25	SAT				-
26	SUN				-
27	7.62				Y
28	7.60				Y
29	7.58				Y
30	7.63				Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: FALL CREEK FARM

Entry Point: LUNCH ROOM EAST SINK

Sample Period: JUNE 2022  
 Month/Year

Number of excursions\* during this month: 8

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 8

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.5"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 7-6-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's