

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	SATURDAY				
2	SUNDAY				
3	7.88		.20	Y	
4	7.86		.20	Y	
5	7.89		.20	Y	
6	7.84		.20	Y	
7	7.84		.20	Y	
8	SATURDAY				
9	SUNDAY				
10	7.87		.20	Y	
11	7.84		.20	Y	
12	7.87		.20	Y	
13	7.85		.20	Y	
14	7.84		.20	Y	
15	SATURDAY				
16	SUNDAY				
17	7.88		.20	Y	
18	7.86		.20	Y	
19	7.89		.20	Y	
20	7.86		.20	Y	
21	7.85		.20	Y	
22	SATURDAY				
23	SUNDAY				
24	7.87		.20	Y	
25	7.84		.20	Y	
26	7.86		.20	Y	
27	7.87		.20	Y	
28	7.86		.20	Y	
29	SATURDAY				
30	SUNDAY				
31	7.88		.20	Y	

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: FALL CREEK FARM

Entry Point: LUNCH ROOM EAST SINK

Sample Period: OCTOBER 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 11-2-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0