

October 2023

Day	pH	Alk	Phos	Other Chlorine	Y/N
1	Sunday				
2	7.52			0.2	Y
3	7.64			0.2	Y
4	7.67			0.2	Y
5	7.65			0.2	Y
6	7.57			0.2	Y
7	Saturday				
8	Sunday				
9	7.64			0.2	Y
10	7.62			0.2	Y
11	7.62			0.2	Y
12	7.72			0.2	Y
13	7.64			0.2	Y
14	Saturday				
15	Sunday				
16	7.79			0.2	Y
17	7.67			0.2	Y
18	7.25			0.2	Y
19	7.77			0.2	Y
20	7.87			0.2	Y
21	Saturday				
22	Sunday				
23	7.64			0.2	Y
24	7.62			0.2	Y
25	7.67			0.2	Y
26	7.78			0.2	Y
27	7.80			0.2	Y
28	Saturday				
29	Sunday				
30	7.72			0.2	Y
31	7.53			0.2	Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Fall Creek Farm & Nursery

Entry Point: Break Room East Side

Sample Period: October 2023
 Month/Year

Number of excursions* during this month: 6
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 6
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: TERESA FASCINATO

Signature: [Signature]

Date: 11-1-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's