

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.67			0.2	Y
2	7.87			0.2	Y
3	7.80			0.2	Y
4	Saturday				
5	Sunday				
6	7.54			0.2	Y
7	7.32			0.2	Y
8	7.35			0.2	Y
9	7.79			0.2	Y
10	7.30			0.2	Y
11	Saturday				
12	Sunday				
13	7.79			0.2	Y
14	7.33			0.2	Y
15	7.67			0.2	Y
16	7.39			0.2	Y
17	7.53			0.2	Y
18	Saturday				
19	Sunday				
20	7.65			0.2	Y
21	7.35			0.2	Y
22	7.35			0.2	Y
23	Thanksgiving				
24	Black Friday				
25	Saturday				
26	Sunday				
27	7.85			0.2	Y
28	7.45			0.2	Y
29	7.60			.2	Y
30	7.75			.2	Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Fall Creek Farm + Nursery

Entry Point: Lunch Room East Sink

Sample Period: NOVEMBER 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH    
 Alk  (Alkalinity)   
 PO4  (Orthophosphate)   
 Other

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 12-9-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's