

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.40			0.2	Y
2	7.52			0.2	Y
3	Saturday				
4	Sunday				
5	7.68			0.2	Y
6	7.45			0.2	Y
7	7.74			0.2	Y
8	7.62			0.2	Y
9	7.68			0.2	Y
10	Saturday				
11	Sunday				
12	7.65			0.2	Y
13	7.77			0.2	Y
14	7.63			0.2	Y
15	7.36			0.2	Y
16	7.35			0.2	Y
17	Saturday				
18	Sunday				
19	7.30			0.2	Y
20	7.40			0.2	Y
21	7.51			0.2	Y
22	7.62			0.2	Y
23	7.53			0.2	Y
24	Saturday				
25	Sunday				
26	7.77			0.2	Y
27	7.75			0.2	Y
28	7.77			0.2	Y
29	7.66			0.2	Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursery

Entry Point: Lunch Room East Sink

Sample Period: February / 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: JERRY FASCINATO
 Signature: *[Signature]*
 Date: 3-4-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0