

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.78			0.2	Y
2	7.67			0.2	Y
3	7.71			0.2	Y
4	Saturday				
5	Sunday				
6	7.57			0.2	Y
7	7.80			0.2	Y
8	7.77			0.2	Y
9	7.89			0.2	Y
10	7.88			0.2	Y
11	Saturday				
12	Sunday				
13	7.47			0.2	Y
14	7.52			0.2	Y
15	7.77			0.2	Y
16	7.66			0.2	Y
17	7.81			0.2	Y
18	Saturday				
19	Sunday				
20	7.54			0.2	Y
21	7.50			0.2	Y
22	7.64			0.2	Y
23	7.62			0.2	Y
24	7.72			0.2	Y
25	Saturday				
26	Sunday				
27	Memorial Day				
28	7.66			0.2	Y
29	7.81			0.2	Y
30	7.77			0.2	Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursery

Entry Point: Lunch Room East Sink

Sample Period: May 2024
Month/Year


Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: JERRY FASCINATO
 Signature: 
 Date: 6-3-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0