

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Saturday				
2	Sunday				
3	7.52		0.2		Y
4	7.62		0.2		Y
5	7.72		0.2		Y
6	7.81		0.2		Y
7	7.54		0.2		Y
8	Saturday				
9	Sunday				
10	7.83		0.2		Y
11	7.47		0.2		Y
12	7.33		0.2		Y
13	7.78		0.2		Y
14	7.47		0.2		Y
15	Saturday				
16	Sunday				
17	7.37		0.2		Y
18	7.42		0.2		Y
19	7.81		0.2		Y
20	7.70		0.2		Y
21	7.55		0.2		Y
22	Saturday				
23	Sunday				
24	7.35		0.2		Y
25	7.31		0.2		Y
26	7.38		0.2		Y
27	7.44		0.2		Y
28	7.41		0.2		Y
29	Saturday				
30	Sunday				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursing

Entry Point: Lock Room East Suck

Sample Period: June 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.5"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: JEFFREY FASCINATO

Signature: [Signature]

Date: 7-2-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0