

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.75			0.2	Y
2	7.74			0.2	Y
3	Saturday				
4	Sunday				
5	7.76			0.2	Y
6	7.71			0.2	Y
7	7.31			0.2	Y
8	7.57			0.2	Y
9	7.91			0.2	Y
10	Saturday				
11	Sunday				
12	7.57			0.2	Y
13	7.74			0.2	Y
14	7.62			0.2	Y
15	7.34			0.2	Y
16	7.32			0.2	Y
17	Saturday				
18	Sunday				
19	7.77			0.2	Y
20	7.47			0.2	Y
21	7.43			0.2	Y
22	7.47			0.2	Y
23	7.73			0.2	Y
24	Saturday				
25	Sunday				
26	7.66			0.2	Y
27	7.52			0.2	Y
28	7.64			0.2	Y
29	7.62			0.2	Y
30	7.74			0.2	Y
31	Saturday				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursery

Entry Point: Lunch Room / East Sink

Sample Period: August 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: JERRY FASCINATO

Signature: *[Signature]*

Date: 9-4-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's