

| Day | pH | Alk | Phos | Other | Y/N |
|-----|----------|-----|------|-------|-----|
| 1 | 7.81 | | | 0.2 | Y |
| 2 | Saturday | | | | |
| 3 | Sunday | | | | |
| 4 | 7.72 | | | 0.2 | Y |
| 5 | 7.82 | | | 0.2 | Y |
| 6 | 7.79 | | | 0.2 | Y |
| 7 | 7.80 | | | 0.2 | Y |
| 8 | 7.76 | | | 0.2 | Y |
| 9 | Saturday | | | | |
| 10 | Sunday | | | | |
| 11 | 7.77 | | | 0.2 | Y |
| 12 | 7.76 | | | 0.2 | Y |
| 13 | 7.63 | | | 0.2 | Y |
| 14 | 7.67 | | | 0.2 | Y |
| 15 | 7.79 | | | 0.2 | Y |
| 16 | Saturday | | | | |
| 17 | Sunday | | | | |
| 18 | 7.79 | | | 0.2 | Y |
| 19 | 7.90 | | | 0.2 | Y |
| 20 | 7.70 | | | 0.2 | Y |
| 21 | 7.80 | | | 0.2 | Y |
| 22 | 7.75 | | | 0.2 | Y |
| 23 | Saturday | | | | |
| 24 | Sunday | | | | |
| 25 | 7.71 | | | 0.2 | Y |
| 26 | 7.83 | | | 0.2 | Y |
| 27 | 7.78 | | | 0.2 | Y |
| 28 | Thursday | | | | |
| 29 | Friday | | | | |
| 30 | Saturday | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 95551

System Name: Fall Creek Farm and Nursery

Entry Point: Luncheon / East Smk

Sample Period: November / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|---|------------------|
| pH | 7.8 | |
| Alk | | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Other | | (_____) |

Print Name: JERRY FACINATO

Signature: [Signature]

Date: 12/4/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0