

Day	pH	Alk	Phos	Other	Y/N
1	Saturday	---	---	---	
2	Sunday	---	---	---	
3	7.31		0.2		Y
4	7.41		0.2		Y
5	7.73		0.2		Y
6	7.53		0.2		Y
7	7.44		0.2		Y
8	Saturday	---	---	---	
9	Sunday	---	---	---	
10	7.73		0.2		Y
11	7.56		0.2		Y
12	7.47		0.2		Y
13	7.81		0.2		Y
14	7.38		0.2		Y
15	Saturday	---	---	---	
16	Sunday	---	---	---	
17	7.43		0.2		Y
18	7.53		0.2		Y
19	7.60		0.2		Y
20	7.56		0.2		Y
21	7.55		0.2		Y
22	Saturday	---	---	---	
23	Sunday	---	---	---	
24	7.42		0.2		Y
25	7.51		0.2		Y
26	7.50		0.2		Y
27	7.57		0.2		Y
28	7.50		0.2		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 95551

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Side

Sample Period: February / 2025
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.5

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 3/13/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0