

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.54			0.2	Y
2	7.21			0.2	Y
3	Saturday				
4	Sunday				
5	7.21			0.2	Y
6	7.72			0.2	Y
7	7.81			0.2	Y
8	7.52			0.2	Y
9	7.32			0.2	Y
10	Saturday				
11	Sunday				
12	7.89			0.2	Y
13	7.40			0.2	Y
14	7.55			0.2	Y
15	7.60			0.2	Y
16	7.53			0.2	Y
17	Saturday				
18	Sunday				
19	7.32			0.2	Y
20	7.70			0.2	Y
21	7.75			0.2	Y
22	7.35			0.2	Y
23	7.73			0.2	Y
24	Saturday				
25	Sunday				
26	Memorial Day				
27	7.25			0.2	Y
28	7.52			0.2	Y
29	7.67			0.2	Y
30	7.71			0.2	Y
31	Saturday				

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

95551

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Sink

Sample Period: May / 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: VERRY FASCINATO

Signature: [Signature]

Date: 6-2-2025

Send to DWP within 10 days after end of
sampling period