

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Sunday				
2	7.32			0.2	Y
3	7.69			0.2	Y
4	7.89			0.2	Y
5	7.68			0.2	Y
6	7.73			0.2	Y
7	Saturday				
8	Sunday				
9	7.23			0.2	Y
10	7.47			0.2	Y
11	7.43			0.2	Y
12	7.71			0.2	Y
13	7.53			0.2	Y
14	Saturday				
15	Sunday				
16	7.52			0.2	Y
17	7.81			0.2	Y
18	7.83			0.2	Y
19	7.84			0.2	Y
20	7.81			0.2	Y
21	Saturday				
22	Sunday				
23	7.72			0.2	Y
24	7.75			0.2	Y
25	7.78			0.2	Y
26	7.62			0.2	Y
27	7.89			0.2	Y
28	Saturday				
29	Sunday				
30	7.29			0.2	Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Smk

Sample Period: June / 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 7-1-2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0