

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.67			0.2	Y
2	Saturday				
3	Sunday				
4	7.57			0.2	Y
5	7.77			0.2	Y
6	7.62			0.2	Y
7	7.73			0.2	Y
8	7.64			0.2	Y
9	Saturday				
10	Sunday				
11	7.58			0.2	Y
12	7.87			0.2	Y
13	7.77			0.2	Y
14	7.67			0.2	Y
15	7.78			0.2	Y
16	Saturday				
17	Sunday				
18	7.61			0.2	Y
19	7.62			0.2	Y
20	7.64			0.2	Y
21	7.60			0.2	Y
22	7.57			0.2	Y
23	Saturday				
24	Sunday				
25	7.76			0.2	Y
26	7.64			0.2	Y
27	7.68			0.2	Y
28	7.69			0.2	Y
29	7.63			0.2	Y
30	Saturday				
31	Sunday				

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Fall Creek Farm and Nursing

Entry Point: Lunchroom / East Sink

Sample Period: August / 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH (Alkalinity)
Alk (Orthophosphate)
PO4 (_____)
Other

Print Name: JERRY FASCINATO

Signature: [Signature]

Date: 9/2/2025

Send to DWP within 10 days after end of
sampling period