

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Labour Day				
2	7.33			0.2	Y
3	7.50			0.2	Y
4	7.88			0.2	Y
5	7.85			0.2	Y
6	Sat				
7	Sun				
8	7.71			0.2	Y
9	7.85			0.2	Y
10	7.75			0.2	Y
11	7.68			0.2	Y
12	7.63			0.2	Y
13	Saturday				
14	Sunday				
15	7.34			0.2	Y
16	7.41			0.2	Y
17	7.32			0.2	Y
18	7.41			0.2	Y
19	7.40			0.2	Y
20	Saturday				
21	Sunday				
22	7.61			0.2	Y
23	7.65			0.2	Y
24	7.67			0.2	Y
25	7.47			0.2	Y
26	7.62			0.2	Y
27	Saturday				
28	Sunday				
29	7.71			0.2	Y
30	7.60			0.2	Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

95551

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Side

Sample Period: September / 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0
Alk 100 (Alkalinity)
PO4 0.1 (Orthophosphate)
Other ()

Print Name: JEFF FASCINATO

Signature: [Signature]

Date: 10/2/2022

Send to DWP within 10 days after end of sampling period