

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.72	—	—	0.2	Y
2	7.71	—	—	0.2	Y
3	7.80	—	—	—	—
4	Saturated	—	—	—	—
5	Saturated	—	—	—	—
6	7.32	—	—	0.2	Y
7	7.78	—	—	0.2	Y
8	7.68	—	—	0.2	Y
9	7.35	—	—	0.2	Y
10	7.32	—	—	0.2	Y
11	Saturated	—	—	—	—
12	Saturated	—	—	—	—
13	7.43	—	—	0.2	Y
14	7.44	—	—	0.2	Y
15	7.48	—	—	0.2	Y
16	7.67	—	—	0.2	Y
17	7.59	—	—	0.2	Y
18	Saturated	—	—	—	—
19	Saturated	—	—	—	—
20	7.81	—	—	0.2	Y
21	7.50	—	—	0.2	Y
22	7.51	—	—	0.2	Y
23	7.50	—	—	0.2	Y
24	7.63	—	—	0.2	Y
25	Saturated	—	—	—	—
26	Saturated	—	—	—	—
27	7.66	—	—	0.2	Y
28	7.77	—	—	0.2	Y
29	7.57	—	—	0.2	Y
30	7.33	—	—	0.2	Y
31	7.57	—	—	0.2	Y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 95551

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Sink

Sample Period: October / 2025
Month/Year


Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: JEFFREY FASCINATO
Signature: 
Date: 11/3/2025

Send to DWP within 10 days after end of
sampling period