

Day	pH	Alk	Phos	Other	Y/N
1	7.57			0.2	Y
2	7.70			0.2	Y
3	7.85			0.2	Y
4	7.35			0.2	Y
5	7.89			0.2	Y
6	Saturday				
7	Sunday				
8	7.88			0.2	Y
9	7.69			0.2	Y
10	7.61			0.2	Y
11	7.21			0.2	Y
12	7.24			0.2	Y
13	Saturday				
14	Sunday				
15	7.20			0.2	Y
16	7.35			0.2	Y
17	7.23			0.2	Y
18	7.21			0.2	Y
19	7.22			0.2	Y
20	Saturday				
21	Sunday				
22	7.29			0.2	Y
23	7.24			0.2	Y
24	Christmas Eve				
25	Christmas Day				
26	7.21			0.2	Y
27	Saturday				
28	Sunday				
29	7.25			0.2	Y
30	7.22			0.2	Y
31	7.31			0.2	Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 5 5 5 1

System Name: Fall Creek Farm and Nursery

Entry Point: Lunchroom / East Sink

Sample Period: December / 2025
Month/Year

Number of excursions* during this month: 8
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 8
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: JERRY FASCINATO

Signature: 

Date: 1-15-2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0