

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name SCRAPER HILL WATER PWS ID# 4100018  
 Month/Year 4 12/ Entry Point: SCRAPER Hill Pump Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:30AM		.39	
2			.39	
3			.38	
4			.37	
5			.37	
6			.37	
7			.37	
8			.39	
9			.39	
10			.41	
11			.41	
12			.40	
13			.41	
14			.40	
15			.40	
16			.39	
17			.37	
18			.37	
19			.39	
20			.41	
21			.40	
22			.38	
23			.38	
24			.38	
25			.41	
26			.40	
27			.40	
28			.39	
29			.39	
30			.38	
31				

Was the chlorine residual ever less than the required minimum residual of .3 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: MONTIE TORRESO Title: MANAGER Operator Certification #: \_\_\_\_\_  
 Signature: [Signature] Phone #: (541)760-1791 OR  
 Date: 5 13 2021 Small Groundwater System