

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Scrauel Hill WATER PWS ID# 41 00018
 Month/Year June 2021 Entry Point: Scrauel Hill Pump Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:30 AM		.38	
2			.38	
3			.37	
4			.39	
5			.39	
6			.40	
7			.41	
8			.41	
9			.41	
10			.40	
11			.41	
12			.40	
13			.38	
14			.39	
15			.41	
16			.41	
17			.40	
18			.40	
19			.39	
20			.39	
21			.39	
22			.37	
23			.37	
24			.37	
25			.39	
26			.39	
27			.41	
28			.41	
29			.40	
30			.38	
31				

Was the chlorine residual ever less than the required minimum residual of .3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: Montie TORGESSON Title: MAAASER Operator Certification #: _____
 Signature: [Signature] Phone #: (541) 760-1791 OR
 Date: 7/1/2021 Small Groundwater System