

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name SCRAVEL HILL WATER PWS ID# 4100018  
 Month/Year Jan 1 2024 Entry Point: SCRAVEL Hill Pump Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 AM		.39	
2			.39	
3			.41	
4			.41	
5			.40	
6			.41	
7			.40	
8			.40	
9			.39	
10			.39	
11			.38	
12			.39	
13			.38	
14			.38	
15			.39	
16			.39	
17			.39	
18			.41	
19			.41	
20			.39	
21			.40	
22			.40	
23			.40	
24			.39	
25			.39	
26			.39	
27			.38	
28			.38	
29			.39	
30			.38	
31			.39	

Was the chlorine residual ever less than the required minimum residual of .3 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: Monty TORRESON Title: MAAGER  
 Signature: [Signature] Phone #: (541) 760-1791  
 Date: 2/1/2024

Operator Certification #: \_\_\_\_\_  
 OR  
 Small Groundwater System