

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Scrauel Hill WATER PWS ID# 4100018
 Month/Year June 1 2024 Entry Point: Scrauel Hill Pump Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00		.38	
2		.39		
3		.39		
4		.41		
5		.41		
6		.42		
7		.41		
8		.41		
9		.41		
10		.40		
11		.42		
12		.42		
13		.42		
14		.41		
15		.42		
16		.42		
17		.40		
18		.40		
19		.40		
20		.42		
21		.42		
22		.42		
23		.43		
24		.42		
25		.41		
26		.41		
27		.40		
28		.40		
29		.41		
30		.40		
31				

Was the chlorine residual ever less than the required minimum residual of .3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: Monty TORGESSON Title: MANAGER Operator Certification #: _____
 Signature: [Signature] Phone #: (541) 760-1791 OR
 Date: 6/30/24 Small Groundwater System