

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Scrauel Hill WATER** PWS ID# **4100018**
 Month/Year **Oct 1 2024** Entry Point: **Scrauel Hill Pump** Required Minimum Residual **.3** mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:30 am		.38	
2			.38	
3			.40	
4			.40	
5			.40	
6			.39	
7			.41	
8			.41	
9			.39	
10			.40	
11			.40	
12			.41	
13			.41	
14			.40	
15			.40	
16			.38	
17			.38	
18			.38	
19			.40	
20			.40	
21			.41	
22			.41	
23			.40	
24			.40	
25			.39	
26			.38	
27			.38	
28			.38	
29			.39	
30			.39	
31			.39	

Was the chlorine residual ever less than the required minimum residual of **.3** mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: **Monty TORGESSON** Title: **MANAGER** Operator Certification #: _____
 Signature: *[Signature]* Phone #: **(541) 760-1791** OR
 Date: **11/1/24** Small Groundwater System