

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Scravel Hill WATER		PWS ID# 4100018	
Month/Year 1 125	Entry Point: Scravel Hill Pump	Required Minimum Residual .3 mg/L	

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10 AM		.41	
2			.41	
3			.40	
4			.40	
5			.41	
6			.40	
7			.40	
8			.40	
9			.41	
10			.41	
11			.39	
12			.39	
13			.40	
14			.41	
15			.42	
16			.41	
17			.42	
18			.40	
19			.41	
20			.40	
21			.39	
22			.39	
23			.41	
24			.41	
25			.39	
26			.39	
27			.40	
28			.39	
29			.39	
30			.39	
31			.40	

Was the chlorine residual ever less than the required minimum residual of **.3** mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: Monty TORRES Signature: _____ Date: 2 21 2025	Title: MANAGER Phone #: (541) 760-1791	Operator Certification #: _____ OR Small Groundwater System <input checked="" type="checkbox"/>
---	---	---