

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Camelot mobile Residence PWS ID# 41-00027
 Month/Year 01 2021 Entry Point: Pumphouse Required Minimum Residual .5 mg/L

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes | |
|------|------|------------------|--|-------|--|
| 1 | 9:00 | Pumphouse | .6 | | |
| 2 | 9:00 | | .5 | | |
| 3 | 9:00 | | .7 | | |
| 4 | 9:00 | | .7 | | |
| 5 | 9:00 | | .9 | | |
| 6 | 9:00 | | .9 | | |
| 7 | 9:00 | | .8 | | |
| 8 | 9:00 | | .8 | | |
| 9 | 9:00 | | .7 | | |
| 10 | 9:00 | | .7 | | |
| 11 | 9:00 | | .7 | | |
| 12 | 9:00 | | .9 | | |
| 13 | 9:00 | | .8 | | |
| 14 | 9:00 | | .9 | | |
| 15 | 9:00 | | .9 | | |
| 16 | 9:00 | | .7 | | |
| 17 | 9:00 | | .8 | | |
| 18 | 9:00 | | .9 | | |
| 19 | 9:00 | | .9 | | |
| 20 | 9:00 | | .7 | | |
| 21 | 9:00 | | .7 | | |
| 22 | 9:00 | | .6 | | |
| 23 | 9:00 | | .9 | | |
| 24 | 9:00 | | .9 | | |
| 25 | 9:00 | | .5 | | |
| 26 | 9:00 | | .5 | | |
| 27 | 9:00 | | .9 | | |
| 28 | 9:00 | | .9 | | |
| 29 | 9:00 | | .7 | | |
| 30 | | | | | |
| 31 | | | | | |

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /

Printed Name: Wanda G. Glade Title: owner
 Signature: Wanda Glade Phone #: (541) 926-2863
 Date: 21 / 1 / 21

Operator Certification #: _____
 OR
 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.