

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Bear Creek MHP
Month/Year 02 125 Entry Point: #51

PWS ID# 4100050
Required Minimum Residual .4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:06a	Wells 1-2-3 Combined	.5	
2	11:26a		.5	
3	10:10a		.5	
4	12:17p		.5	
5	10:58a		.5	
6	1:56p		.5	
7	1:40p		.5	
8	10:21a		.5	
9	11:16a		.5	
10	8:50a		.5	
11	8:41a		.5	
12	10:41a		.5	
13	9:15a		.5	
14	9:48a		.5	
15	12:44p		.5	
16	11:26a		.5	
17	10am		.5	
18	9:33a		.5	
19	10:46a		.5	
20	9:33a		.5	
21	9:41a		.5	
22	11:46a		.5	
23	11:01a		.5	
24	9:27a		.5	
25	9:56a		.5	
26	10:24a		.5	
27	10:12a		.5	
28	9:35a		.5	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☒ No
If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Mike Skinner

Signature: Mike Skinner

Date: 03 10 1205

Title: Water System Operator

Phone #: (541) 714-8434

Operator Certification #:

OR

Small Groundwater System ☒

Return by 10th of following month by either email : fax
971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019