

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Bear Creek MHP

PWS ID# 41 00050

Month/Year 03 125 Entry Point at 51

Required Minimum Residual .4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:34 p	Wells 1-2-3 Combined	.55	
2	12:41 p		.55	
3	9:56 a		.5	
4	8:47 a		.55	
5	2:51 p		.5	
6	9:27 a		.5	
7	10:19 a		.5	
8	1:20 p		.5	
9	10:18 a		.55	
10	9:37 a		.55	
11	10:37 a		.55	
12	9:50 a		.5	
13	1:04 p		.5	
14	10:15 a		.5	
15	10:17 a		.5	
16	11:41 a		.5	
17	10:35		.5	
18	9:25 a		.5	
19	10:15 a		.55	
20	9:41 a		.5	
21	9:20 a		.5	
22	8:55 a		.5	
23	11:26 a		.5	
24	10:07 a		.5	
25	9:03 a		.5	
26	8:28 a		.5	
27	8:56 a		.5	
28	11:10 a		.5	
29	12:15 p		.5	
30	11:46 a		.5	
31	9:23 a		.5	

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____

Date it was returned to service: _____ / _____ / _____

Printed Name: Mike Skinner

Title: Water System Operator

Operator Certification #: _____

Signature: Mike Skinner

Phone #: (541) 414-8434

OR

Date: 04 10 12025

Small Groundwater System ☒

Return by 10th of following month by either email : fax
971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019