

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Bear Creek MHP PWS ID# 4100050
Month/Year Apr V 2025 Entry Point 51 Required Minimum Residual .4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:51 a	Wells 1-2-3 combined	.5	
2	9:51 a		.5	
3	10:21 a		.5	
4	9:18 a		.5	
5	9:55 a		.5	
6	11:11 a		.5	
7	10:05 a		.5	
8	9:30 a		.5	
9	10:43 a		.5	
10	10:14 a		.5	
11	11:10 a		.5	
12	11:41 a		.5	
13	11:06 a		.5	
14	10:25 a		.5	
15	10:09 a		.5	
16	9:46 a		.5	
17	10 a.m.		.5	
18	10:51 a		.5	
19	10:46 a		.5	
20	11:27 a		.5	
21	9:14 a		.5	
22	9:57 a		.5	
23	9:45 a		.5	
24	9:16 a		.5	
25	10:51 a		.5	
26	10:15 a		.5	
27	11:21 a		.5	
28	1 PM		.5	
29	11:33 a		.5	
30	10:14 a		.5	
31				

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? ☐ Yes ☒ No
If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____

Date it was returned to service: _____ / _____ / _____

Printed Name: M. Ke Skinner

Signature: M. Ke Skinner

Date: 5/12/2025

Title: Water System Operator

Phone #: (541) 414-8444

Operator Certification #: _____

OR

Small Groundwater System ☒

Return by 10th of following month by either email : fax
971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019